

SHOULD WE HIRE OUT LEADS TO CAMPERS?

YOU CAN BUT YOU NEED TO BE AWARE OF YOUR RESPONSIBILITIES AS A "HIREE"

- The lead must have a current tag confirming that it has been inspected and tested in accordance with AS/NZS 3760:2010.
- These leads need to be tested and tagged every three months.
- Each time you hire the lead it must also be visually inspected for any splits, exposed wires, bulges, scorching or damage. **DO NOT HIRE OUT DAMAGED LEADS.**
- Instruct the hirer to plug it in, trip the RCD then reset before use. If the RCD fails the lead must be returned to the office and replaced.
- Document clearly that the lead has a current tag and has been visually inspected before hiring. You sign and they sign.

Inform the Hirer that one supply lead shall be connected to one socket outlet.

Any supply lead used to connect to a transportable structure, such as a caravan or tent, should be in one unbroken length. You cannot use extension cords.

Double adapters are non-compliant.

The lead must not be connected while coiled on a drum, reel or storage box. It must be fully uncoiled while in use.

The above information is provided to all members of Holiday Parks Association of New Zealand by ElectriSAFE NZ Ltd.
The information is current and up-to-date as of 25 September 2014

ElectriSAFE is a member of HAPNZ and available to assist you with all electrical compliance requirements. If you would like to discuss any of the above recommendations please contact Mike on 0274 822 708 or mike@electrisafe.co.nz